TEST REPORT

DATE: 05-29-2018	Page 1 of 1	TEST NUMBER: 0247100
CLIENT	Egetaepper a/s	

TEST METHOD CONDUCTED	ASTM E662 Smoke Density (Flaming) Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials also referenced as NFPA 258
-----------------------	---



	DESCRIPTION OF TEST SAMPLE
IDENTIFICATION	Epoca Classic Wt
CONSTRUCTION	Loop Pile
BACKING	Woven Synthetic

GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

	CON	DITIONS	
PREDRYING OF TEST SAMPLE CONDITIONING OF TEST SAMPLE TESTING CONDITION	24 Hours at 140° F 24 Hours at 70° F As Received	and 50% Relative Humidity	
FURNACE VOLTAGE CHAMBER TEMPERATURE TEST MODE	118 V 95° F Flaming	IRRADIANCE CHAMBER PRESSURE	2.5 watts/sq cm 3" H ₂ O

AVERAGE MAXIMUM DENSITY CORRECTE		FLAMING	200
AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			240
	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	249.0	264.0	239.0
Time to Dm (minutes)	2.5	3.5	2.0
Clear Beam (Dc)	50.0	56.0	46.0
Corr. Max Density (Dmc)	199.0	208.0	193.0
Density at 1.5 minutes	78.0	89.0	64.0
Density at 4.0 minutes	243.0	250.0	226.0
Time to 90% Dm (minutes)	1.5	2.0	1.5
Specimen Weight (grams)	12.9	12.7	12.7

^{*} This sample PASSES the requirements of 450 or less.

Day asbury

APPROVED BY:

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public



714 Glenwood Place

Dalton, GA 30721

706-226-3283

Fax: 706-226-6787

protest@optilink.us

TEST REPORT

Page 1 of 1	TEST NUMBER:	0247100
Egetaepper a/s		
	TANK TANKS	

TEST METHOD CONDUCTED	ASTM E662 Smoke Density (Non-Flaming) Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials also referenced as NFPA 258
-----------------------	---



And the second second	DESCRIPTION OF TEST SAMPLE
IDENTIFICATION	Epoca Classic Wt
CONSTRUCTION	Loop Pile
BACKING	Woven Synthetic

GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

CONDITIONS				
PREDRYING OF TEST SAMPLE CONDITIONING OF TEST SAMPLE TESTING CONDITION	24 Hours at 140° F 24 Hours at 70° F and 50% Relative Humidity As Received			
FURNACE VOLTAGE CHAMBER TEMPERATURE TEST MODE	118 V 95° F Non-Flaming	IRRADIANCE CHAMBER PRESSURE	2.5 watts/sq cm 3" H ₂ O	

AVERAGE MAXIMUM DENSITY CORRECTE	D (Dmc)	NON-FLAMING	196
AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			84
	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	206.0	219.0	196.0
Time to Dm (minutes)	15.0	17.0	14.5
Clear Beam (Dc)	10.0	14.0	8.0
Corr. Max Density (Dmc)	196.0	205.0	188.0
Density at 1.5 minutes	40.0	55.0	36.0
Density at 4.0 minutes	82.0	98.0	72.0
Time to 90% Dm (minutes)	12.5	13.0	11.5
Specimen Weight (grams)	12.8	12.8	12.9

^{*} This sample PASSES the requirements of 450 or less.

APPROVED BY:

This facility is accredited by the Na Lab Code 100297. This accreditation

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed it may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



714 Glenwood Place

Dalton, GA 30721

706-226-3283

Fax: 706-226-6787

protest@optilink.us