

Ege Carpets A/S Industrivej Nord 25 7400 Herning Denmark Your Reference

Customer Number 40201

Contact Person Weissenborn Lene

E-Mail

lbm@ege.dk

Vienna / 11.10.2023 / guse

# Test Report VN720 227811.1

## **Application**

Testing and classification according to EN 1307 as well as suitability for use on stairs.

## **Test Material**

Graphic 80/20 1300 LF

The test material used for testing was made anonymous for laboratory purposes. A detailed sample list is included in the document.

### Issuing

Original Issuing, 11.10.2023

Number Of Included Pages: 8

Guth Sens

OETI - Institut fuer Oekologie, Technik und Innovation GmbH

Günther Sereinig

**Customer Service Officer** 





# 1 Application

Date of Order	Scope of Order	
31.08.2023	Summarized test report - EN 1307 Annex B	
	Description Of Specimen - Textile Floor Coverings - EN 1307	
	Mass Per Unit Area - ISO 8543 Textile Floor Coverings	
	Thickness Of Textile Floor Coverings - ISO 1765	
	Thickness Wear Layer Of Textile Floor Coverings - ISO 1766	
	Pile Density - ISO 8543	
	Number Of Tufts Or Loops - ISO 1763	
	Basic requirements - EN 1307 -Textile floor covering with ≥ 80 % natural fibre in pile	
	Changes in Appearance - Drum Test - ISO 10361 Method A / EN ISO 9405	
	Classification - EN 1307 -Textile floor covering with ≥ 80 % natural fibre in pile	
	Suitability For Use On Stairs - EN ISO 12951, Test B	

## 2 Samples

No.	Receipt	Sample Identification
1	07.09.2023	Graphic 80/20 1300 LF

(Unless otherwise stated samples are provided by the customer.)



## 3 Tests Performed / Results

		Graphic 80/20 1300 LF
Summarized test report EN 1307 Annex B *		
Number of Tests - Identification, basic information		1
Product name		Graphic 80/20 1300 LF
Type of face side		Cut Pile (according to B.2.2: A1)
Manufacturing procedure		Tufted (according to B.2.1: M5)
Backing		Textile Backing (according to B.2.4: S10) (non-woven-fabric)
Type of floor covering		textile floor covering with pile
Base		Woven fabric (according to B.2.3: P1)
Colouration		multicolored patterned (according to B.2.5: C2)
Dimensions		rolls
Fibers of pile		80% WO / 20% PA (declaration by the applicant)
Construction		
Total mass	[g/m²]	2'373
Pile mass above the substrate	[g/m²]	825
Total thickness	[mm]	11.8
Thickness of pile layer	[mm]	6.6
Surface pile density	[g/cm³]	0.125
Number of tufts or loops per dm <sup>2</sup>		1'237
Appearance change		
Vettermann-drum test, short time		3.5
testing Vettermann-drum test, long time testing Classification according EN 1307		3.0
Basic requirements		fulfilled
Use class		Class 33
Luxury-Class		LC 4
Additional properties		
Stair suitability		suitable for intensive use



1 tufted cut pile woven fabric multicoloured patterned textile backing (non-woven) 80% WO / 20% PA (declaration by the applicant) rolls
tufted cut pile woven fabric multicoloured patterned textile backing (non-woven) 80% WO / 20% PA (declaration by the applicant)
cut pile woven fabric multicoloured patterned textile backing (non-woven) 80% WO / 20% PA (declaration by the applicant)
woven fabric multicoloured patterned textile backing (non-woven) 80% WO / 20% PA (declaration by the applicant)
multicoloured patterned textile backing (non-woven) 80% WO / 20% PA (declaration by the applicant)
textile backing (non-woven) 80% WO / 20% PA (declaration by the applicant)
80% WO / 20% PA (declaration by the applicant)
rolls
textile floor covering with pile
1 4
20
65
2'373
1.3
50
0.84
1 4
20
65
11.8
0.7
0.2
1.47



		Graphic 80/20 1300 LF
<b>Thickness Wear Layer Of Textile Floor Co</b> ISO 1766	overings	
Number of Tests • Number of specimen		1 4
Conditioning		
Temperature	[°C]	20
Air humidity	[%]	65
Shearing methode		<del></del>
Thickness of wear layer		
Mean value	[mm]	6.6
Coefficient of variation	[%]	1.6
Confidence interval (95%) abs. width	[mm]	0.2
Measurement uncertainty	[%]	1.87
• Issue Date of Standard: 1999-10		
Pile Density ISO 8543		
Number of Tests • Number of specimen		1 4
Pile material		80% WO / 20% PA
Density of pile material	[g/cm³]	1.28
Mass of pile per unit area	[g/m²]	825
Thickness of pile layer	[mm]	6.6
Surface pile density	[g/cm³]	0.125
Relative surface pile density	[%]	9.7
Issue Date of Standard: 2020-06		
Number Of Tufts Or Loops ISO 1763		
Number of Tests • Number of specimen		1 4
• Number of tufts or loops / 10 cm		
Longitudinal direction		38.9
Cross direction		31.8
Number of tufts or loops per dm²		1'237
Number of tufts or loops per m²		123'700
Issue Date of Standard: 2020-07		



		Graphic 80/20 1300 LF	
Basic requirements EN 1307 -Textile floor covering with ≥ 80 % n in pile *	atural fibre		
Number of Tests • Colour fastness	[grade]	1 Conformity shall be indicated for each color by the manufacturer	
• Fibre bind - cut pile - EN 1963 Method A		Wool content > 80% therefore no basic requirements required	
Basic requirements		fulfilled	
Changes in Appearance - Drum Test ISO 10361 Method A / EN ISO 9405			
Number of Tests • Used scale		1 ISO cut (ISO - B)	
• Appearance change 5'000 cycles (if dominant: attribute)			
Assessor 1	[grade]	3.5	
Assessor 2	[grade]	3.0	
Assessor 3	[grade]	3.5	
Median	[grade]	3.5	
Mean value	[grade]	3.3	
• Index of colour change 5'000 cycles			
Assessor 1	[grade]	3 - 4	
Assessor 2	[grade]	4	
Assessor 3	[grade]	4	
Median	[grade]	4	
Appearance change 20'000 cycles (if dominant: attribute)	for and all		
Assessor 1	[grade]	3.0	
Assessor 2	[grade]	2.5	
Assessor 3	[grade]	3.0	
Median	[grade]	3.0	
Mean value	[grade]	2.8	
Index of colour change 20'000 cycles			
Assessor 1	[grade]	3	
Assessor 2	[grade]	3 - 4	
Assessor 3	[grade]	3	
Median	[grade]	3	
Damages by treatment		No	
Measurement uncertainty: ± 0.5	[']	± 0,5	
<ul> <li>Issue Date of Standard EN ISO 9405: 2017-06</li> <li>Issue Date of Standard ISO 10361: 2015- 02</li> </ul>			



		Graphic 80/20 1300 LF
Classification EN 1307 -Textile floor covering with ≥ 80 % fibre in pile *	natural	
Number of Tests  • Appearance change - short time test	[grade]	1 3.5
Appearance change - long time test	[grade]	3.0
• Add.mand.requClass 32: Pile desity ≥ 0,10 g/cm³		0.125
Level of use classification		Class 33
• Luxury-Class		LC 4
Suitability For Use On Stairs EN ISO 12951, Test B		
Number of Tests • Number of specimen		1 4
Median of appearance change in the edge area	[grade]	low
Assessment		suitable for intensive use
Issue Date of Standard: 2020-06		



#### 4 Remarks

#### Period of Validity

There are no regulations concerning duration of validity in the individual test standards. As the results of the examinations refer only to the submitted and examined samples, the report is valid for these for an unlimited period. A period of validity specified as part of an expert evaluation is in the discretion of the consultant or OETI. The applicability of results and expert evaluations for materials not tested is in the responsibility of the applicant. Whereby an apportionment of results as well as any specified period of validity can only be done for identically constructed products and only as long as the product is produced unchanged. Possible national or international restrictions concerning the terms of usability of test and classification reports have to be considered; this is not the responsibility of the test laboratory.

#### **Sample Material**

Results of performed tests only refer to the sample material provided. The testing period is defined as timeframe between receipt of samples and issue date of test report. Without explicit written other agreement testing is destructive and the sample material is transferred to the property of OETI, which is entitled to freely decide on storage and disposal.

#### Issuing

This test report is only issued as a PDF. Translations will be marked accordingly on the cover sheet.

#### **Quality Management, Accreditation And Notification**

All tests and services are performed under a quality management system according to EN ISO/IEC 17025. OETI is accredited as Testing Laboratory and Certification Body for products. It also is a Notified Body (NB0534). (see http://ec.europa.eu/enterprise/newapproach/nando/). Accreditation was provided by Akkreditierung Austria. The scope of accreditation is listed on www.oeti.biz. Due to the system for the mutual recognition of national accreditations (ILAC/IAF), this accreditation is valid worldwide.

Statements of conformity are based on the specifications of the specified standard. The "simple acceptance rule" applies, that means the measurement uncertainty is stated for the statement of conformity, but not taken into account.

In this report individual non-accredited test procedures are marked with \*. Nevertheless, the analysis was also carried out for these parameters at the same level of quality as for the accredited parameters. The accreditation marking refers to the time of the first issuance of the report.

According to the decree on the use of the accreditation mark ("AkkZV") the accredited Conformity Assessment Body is the only one to use the accreditation mark. Application of the registration number of the Notified Body: As to personal protective equipment (PPE) the requirements of Regulation (EU) 2016/425 have to be kept. With construction products the application is only permitted within the declaration of performance for CE-marking.

### **Copyright And Usage Notes**

It is pointed out, that any alterations, amendments or falsifications of reports not authorized by the issuer of the report will be prosecuted as civil and criminal offences; this especially to the appropriate requirements of ABGB, UrhG, UWG and criminal law and their respective international equivalents. Reports are protected under international copyright laws. Written consent of the OETI GmbH is required for publications (also in excerpt) and reference to tests for public relation purposes. Reports may only be reproduced in full length.

End of Report